CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date	20160609-MH27530 MH27530-20000802 2016-JUNE-09
Issued to:	ROTH INDUSTRIES INC 268 BELLEW AVE S WATERTOWN NY 13601
This is to certify that representative samples of	NONMETALLIC TANKS FOR OIL-BURNER FUELS AND OTHER COMBUSTIBLE LIQUIDS Refer to addendum page for Models/Product Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	CAN/ULC-S670-14 - Standard for Nonmetallic Tanks for Oil Burner Fuels and Other Combustible Liquids Subject 2258 - Outline of Investigation for Nonmetallic Tanks for Oil-Burner Fuels and Other Combustible Liquids
Additional Information:	See the UL Online Certifications Directory at <u>www.ul.com/database</u> for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

Bruce Mahrenholz, Director North American Certification Progra UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date 20160609-MH27530 MH27530-20000802 2016-JUNE-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL – Aboveground, nonmetallic, rectangular, diked (USA tank identifier)/closed secondary containment (Canadian tank identifier) tanks (nonmetallic primary tank within a metallic dike), with integral support and handles, for oil-burner fuels and other combustible liquids, for indoor or outdoor use for the following Models: 400L (400L/110 USG), 620L (620 L/165 USG), 1000L (1000 L/275 USG), 1000LH (1000 L/275 USG) and 1500L (1500 L/400 USG).

NOTE: This UL/ULC Listing covers only the tank design(s) indicated above. Any additional tank designs and models will require separate evaluation and approval prior to labelling with the UL/ULC mark.

Barkelly

Bruce Mahrenholz, Director North American Certification Program



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/