



TB 028-15

Regulatory Acceptance-Wisconsin Department of Agriculture, Trade and Consumer Protection

Product: Roth DWT Lube Oil Storage Tanks

Date: January 28, 2015 (supersedes Tech Bulletin dated March 27, 2014)

Purpose:

This bulletin is to inform our sales channel members and customers of the acceptance of the UL SU 2258 product standard by the Wisconsin Department of Agriculture Trade and Consumer Protection and its incorporation in the WI Administrative Code.

Explanation:

The Wisconsin Department of Agriculture Trade and Consumer Protection, (WI DATCP), has included UL SU 2258, the product standard to which the Roth DWT is certified, to the Wisconsin Administrative Code. A directory to this citation is as follows:

Wisconsin Administrative Code-Chapter ATPC 93 Flammable, Combustible and Hazardous Liquids

Subchapter II Adopted Standards and General Requirements

Section ATPC 93.250 Tank construction and marking

An excerpt from this section of the Wisconsin Administrative Code is shown below.

Construction. Tanks containing flammable or combustible liquids shall be constructed to one of the recognized design standards in NFPA 30 section 21.4.2, **or to another standard or design approved by the department**, except this requirement does not apply to any of the following tanks:

ATCP 93.250(2)(a) (a) Tanks that contain liquids which are also hazardous substances.

ATCP 93.250 Note Note: Section ATPC 93.350 requires hazardous substance tanks to be designed and constructed under the supervision of a qualified engineer.

ATCP 93.250(2)(b) (b) Tank wagons, farm tanks and tank vehicles used in accordance with the requirements in ss. ATPC 93.610 and 93.630, for fuel dispensing from aboveground tanks and at farms and construction projects.

ATCP 93.250 Note: Design standards recognized by NFPA 30 section 21.4.2 include API 12B, API 12D, API 12F, API 650, UL 58, UL 80, UL 142, UL 1316, UL 1746, UL 2080 and UL 2085. Another standard approved by the department is SU 2258 from Underwriters Laboratories Inc.



TB 028-15 Regulatory Acceptance

January 28, 2015

ATCP 93.250 Note Note: Tank wagons have construction requirements in section ATCP 93.610 (1). Farm tanks are required to meet the construction specifications in NFPA 30A section 13.2.3. Tank vehicles are required to meet the construction specifications in NFPA 385 chapters 2 and 3. Movable tanks covered under the dispensing requirements in section ATCP 93.610 (2) are not exempted from this requirement.

ATCP 93.250(2)(c) (c) Tanks which are custom built for a specific purpose and which are supported by a statement acceptable to the department, from a qualified engineer, as defined in s. ATCP 93.350 (2) (d), except the competency of the engineer shall relate to the purpose for the custom-built tank.

ATCP 93.250(2)(d) (d) Aboveground used-oil tanks at a scrap recycling or auto recycling facility that are exempted from these requirements under s. ATCP 93.300 (9).

Although the title of this code includes Flammable, Combustible and Hazardous Liquids, please remember that the Roth DWT is applicable to *combustible* liquid storage only.

For any questions or inquiries regarding this Technical Bulletin, please contact the Roth Technical Department per the contact information below